



DET NORSKE VERITAS

TYPE APPROVAL CERTIFICATE

CERTIFICATE NO. E-8566

This Certificate consists of 3 pages

This is to certify that the
Low Voltage Cable
with type designation(s)
HXXM Signal Cable 0,6/1 kV

Manufactured by
Draka Marine, Oil & Gas International
Houston, TX 77032, United States

is found to comply with
Det Norske Veritas' Rules for Classification of Ships, High Speed & Light Craft and Det Norske Veritas' Offshore Standards

IEC 60092-353 (2001-04)

IEC 60332-3-22 (2000-10)

IEC 60754-1 (1994-01)

IEC 60754-2 (1997-04)

IEC 61034-2 (2005-04)


Application
Instrumentation and communication. Halogen free. Low smoke. Enhanced insulation according to IEC 60092-353 Annex A.

Voltage class (V)	0,6/1 kV
Temp. class (°C)	90

Place and date

Høvik, 2008-01-21

for DET NORSKE VERITAS AS


Marit Laumann
Head of Section



Local Office
DNV Rotterdam

This Certificate is valid until

2010-12-31


Erik Hoffmann (Vabn)
Surveyor

Notice: This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

If any person suffers loss or damage which is proved to have been caused by any negligent act or omission of Det Norske Veritas, then Det Norske Veritas shall pay compensation to such person for his proved direct loss or damage. However, the compensation shall not exceed an amount equal to ten times the fee charged for the service in question, provided that the maximum compensation shall never exceed USD 2 million. In this provision "Det Norske Veritas" shall mean the Foundation Det Norske Veritas as well as all its subsidiaries, directors, officers, employees, agents and any other acting on behalf of Det Norske Veritas.



Cert. No.: E-8566
File No.: 827.20

Name and place of manufacturer

Draka Kabel B.V.
Amsterdam
Netherlands

Product description

Type: HXXM Signal cable 0,6/1 kV

Conductors: Plain stranded copper class 2
Core insulation: XLPE or HF XPLE
Screen: Individual screen
Outer sheath: SHF1

Number of cores x conductor cross-section mm ²	Nominal overall diameter mm
1 x 2 x 1,0	8,9
2 x 2 x 1,0	14,4
4 x 2 x 1,0	17,1
10 x 2 x 1,0	25,0
12 x 2 x 1,0	26,6
16 x 2 x 1,0	30,1
1 x 2 x 1,5	9,4

Number of cores x conductor cross-section mm ²	Nominal overall diameter mm
2 x 2 x 1,5	15,4
5 x 2 x 1,5	20,3
12 x 2 x 1,5	28,7
12 x 2 x 2,5	32,5
2 x 2 x 4	20,0

Number of cores x conductor cross-section mm ²	Nominal overall diameter mm
1 x 3 x 1,0	9,4
1 x 3 x 1,5	10,0
10 x 3 x 1,5	31,5
16 x 3 x 1,5	36,8

Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Type Approval documentation

Data sheets: HXXM(B)(FR)EEP.xls-RH1998-001 dated 98-11-06
RD/NC/9814B dated 98-06-25 updated 98-09-28

Test reports: Intertek Testing Services no. J98*16608-001 Appendix A dated 98-08-06,
letter ITS report with oil test results, dated December 2, 2002 and ITS report
crush resistance and impact test dated 2003-05-02.



Cert. No.: E-8566
File No.: 827.20

Tests carried out

Type tests according to IEC 60092-3, IEC 60092-353, IEC 60332-3-22, IEC 60754-1/2, Mil-C-24643A cl. 4.7.25 and cl 4.7.26, IEC 61034-1/2, IEEE Std-45 performance tests, NES 711, Mil-C-24643A cl. 4.7.27, NES 713, Mil-C-24643A cl. 4.7.29, CSA C22.2 No 0.3 (cold bend – 40 °C, cold impact – 35 °C), IEEE 45 par. 9.13.7 oil test and UL 1581 sect. 1200 and crush and impact test UL 1277, UL 2225, UL 1569.

Marking of product

Product marking: DRAKA 02 or 03 - HXXM Signal Cable - size – 0,6/1 kV

Certificate retention survey

The scope of the retention/renewal survey is to verify that the conditions stipulated for the Type approval is complied with and that no alterations are made to the product design or choice of materials.

The main elements of the survey are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Production Sample Tests (PST) and Routines (RT) checked (if not available tests according to PST and RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Survey to be performed at least every second year.

END OF CERTIFICATE