



Intertek Testing Services

ETL SEMKO

Mr. Gerard van Hoeijen
Draka Nederland B.V.
PO Box 1117
1000 BC Amsterdam
The Netherlands

Mr. van Hoeijen,

The testing of the HXXM, HXXM-FR, HXXM-B, and HXXM-B FR product manufactured by Draka Nederland B.V. to the Cable Immersion in Oil test as detailed in IEEE-45: 1998 edition, paragraph 8.13.7, has been completed and found to and comply with the requirements of this test.

A handwritten signature in black ink that reads 'Chuck Barlow'.

Chuck Barlow
Associate Engineer
Cabling Products Testing Group

Cc: Mr. Walter Constantine – Draka USA
Mr. Jeff Eby – Eby Energy Products